

4. CLASSIFICATION AND FIELD OF APPLICATION

4.1 REFERENCE OF CLASSIFICATION

This classification has been carried out in accordance with clause 11 of EN 13501-1:2018.

4.2 CLASSIFICATION

The product, **Multifunctional polyester wall covering**, in relation to its reaction to fire behaviour is classified:

C

The additional classification in relation to smoke production is:

s1

The additional classification in relation to flaming droplets / particles is:

d1

Reaction to fire classification: C – s1, d1

4.3 FIELD OF APPLICATION

This classification is valid for the following product parameters:

Thickness	5-6 mm
Surface density	710 g/m ² (mounting glue excluded)
Substrate	(Minimum class A2 according to EN 13238:2010)
Colour	Full colour / black (printed: Dyesub)
Air gap	40 mm, not ventilated
Methods and means of fixing	Product glued to substrate, 600 g/m ²
Joints	Not applicable
Other aspects of end use conditions	Closed surface, no openings or gaps between components

4.4 DURATION OF THE VALIDITY OF THIS CLASSIFICATION REPORT

There are no limitations in time on the validity of this report.

5. LIMITATIONS

This classification document does not represent type approval or certification of the product.



A.H.L.M. Zwinkels B.Sc.
Project leader reaction to fire



A. González Santamaría M.Sc.
Project leader reaction to fire